



USB Driver Installation Instructions for Stratus II

Windows XP

- 1) Download the CRIUSB.INF file from the Stratus II homepage: www.controlresources.com/variable-frequency-drive-smartfan-stratus-ii/
- 2) Connect a USB cable from the Stratus II to the Computer and apply power.
- 3) The “Found New Hardware Wizard” will open
- 4) If shown, select “No, not this time”, then click Next
- 5) Select “Install from a list or specific location”, then click Next
- 6) Select “Search for the best driver in these locations”
- 7) Select “Include this location in the search:”, then click Browse
- 8) Locate the folder where the CRIUSB.INF file was downloaded to and click “Next”.
- 9) If a security warning window appears, click “Continue Anyway” then click “Finish”
- 10) Determine the Com Port Number at Device Manager/Ports/Stratus II Communications

Windows 7

- 1) Download the CRIUSB.INF file from the Stratus II homepage: www.controlresources.com/variable-frequency-drive-smartfan-stratus-ii/
- 2) Connect a USB cable from the Stratus II to the Computer and apply power.
- 3) Windows will fail to install the driver on its own.
- 4) Open the Device Manager in Control Panel and double click on “Stratus II Communications” under “Other Devices”
- 5) Click Update Driver and select “Browse my computer for driver software”.
- 6) Click Browse and locate the folder where the CRIUSB.INF file was downloaded to.
- 7) Click OK and Next. If you get a security warning, Click “Install this driver software”.
- 8) That is it. Windows has successfully updated your software driver. You will see “STRATUS II COMMUNICATIONS (COM#)” under the Ports branch in Device Manager. Make note of which COM port was assigned to the Stratus II.